9332

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130 Article 13C)

OWNER OR CONTRACTOR Robert Cook DATE 8-14-89 PERMIT NO. B-11

PHONE: Business _____ Home _____

LOCATION Connor Country Dr. + Genuss Co Dr. S. R. No. _____

SUBDIVISION NAME Baymount LOT NO. 37 SECTION OR BLOCK NO. I

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes ( ) No ( )

Lot Area 2.60 acres

Character & Porosity of Soil Enfaula Sandy loam

Percolation Rate 4 gal/sq ft/day

Topography Level to slight slope

Depth to Water Table 10'+

Rock or other impervious formations none

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement

Size of Tank 1250 Gals.


Nitrification Field:

No. of Lines 2

Sq. Ft. 700 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)



Genuss Plot of System

Installed by Tommy Cothern

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 8-14-89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold