IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jay Hall DATE June 29, 1977 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Old Mocksville Rd N. #2158, house on Rt before Rd #2169 (Chestnut Grove Rd.) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	Character & Porosity of Soil	Cecil Clay
Auto. Dishwasher	Yes ( )	No ( )	Percolation Rate	none
Auto. Wash. Machine	Yes ( )	No ( )	Topography	2-6%
Site Suitable	Yes ( )	No ( )	Depth to Water Table	unk
			Rock or other impervious formations	none found

Lot Area _____

Repair



Plot of System

Size of Tank existing Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft 375+ Linear Ft. 150
Depth of Stone in Lines 18"
Water Supply: Individual ( )
Public ( )

Installed by Henry Seamon

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Lacy DATE 6/29/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold