PIN 4756 972767 George Nelson Bevard 242 Country Dr. Statesville

Permit # ~~1065~~ 200455

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dr. Richard Falls DATE 4-21-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Rd # 2171 TL in to Baymount Meadows


SUBDIVISION NAME Baymount Meadows S. R. No. _____

LOT NO. 2 SECTION OR BLOCK NO. A

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3½

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	@ 70 ±
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	1" — 60 min
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none
Lot Area 2 Acres			Rock or other impervious formations	none



Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 16"

Water Supply: Individual (✓)

Public ( )

Installed by Donald Lackey

System

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

Location of the proposed Detached Garage addition does not appear to impact the existing on-site septic system.**NOTE: _____

_____ REHS

Date: December 2, 2013

ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY _____ DATE 4/21/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold