DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #: _____
COUNTY: IREDELL


SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM 4756-98-6378

OWNER: G.L. WILSON BLDG, CO APPLICANT: TOM WILSON
ADDRESS: 190 WILSON PARK RD STVL, 28625 APPLICATION DATE: 3-25-04 DATE EVALUATED: 5-4-04
PROPOSED FACILITY: PRIVATE SHOP PROPOSED DESIGN FLOW (.1949): 100 PROPERTY SIZE: 52.25 ACRES
LOCATION OF SITE: OLD MOCKSVILLE RD NE ON LEFT ACROSS FROM CHESTNUT GROVE ROAD PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 15%	0-4	GR L	VFR SSPP					PS 0.3
		4-40	SBK C	FR SSPP					
		40-48	SBK CL	FR SSPP					
2	L 12%	0-3	GR L	VFR SSPP					PS 0.3
		3-33	SBK C	FR SSPP					
		33-48	SBK CL	FR SSPP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: TOM WILSON


NORTH
EXISTING BARN
DRIVE
GARAGE
2
1