DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	10% LS	0-3"	cl, med, sbk	fr, ss, so, non		>48"			PS .35
		3-12"	c, med, sbk	fr, ss, so, sp					
		12-48"	loamy sand	fr, ss, so, sp					
2	10% LS	0-3"	cl, med, sbk	fr, ss, so, sp		>48"			PS .5
		3-12"	c, med, sbk	fr, ss, so, sp					
		12-48"	loamy sand	fr, ss, so, sp					
3	10%	0-3"	cl, m, sbk	fr, ss, so, sp		>48"			PS .35
		3-26"	c, m, sbk	fr, ss, so, sp					
		26-48"	c, m, sbk	fr, ss, so, sp					
4	10%	0-15"	cl, m, sbk	fr, ss, so, sp					
		24-36"	loamy sand	fr, ss, so, sp					
		36"	rock						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	conv. trench	conv. trench
Site LTAR	.35	.35

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): SS
EVALUATED BY: J. COOK
OTHER(S) PRESENT: _____