IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Glenn Millsaps DATE 8-2-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N TL on Rd # 1921 before Bethany Presbyterian Ch on left at end of Maintenance Rd. S. R. No. 1921


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	red clay	
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	one burning	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to back	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none	
			Rock or other impervious formations	none	

Lot Area 150 X 156



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Harlee Lackey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Z. Dr. DATE 8/2/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold