IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

Alfred Lowe (Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Eshmen DATE 1 March 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION N. N. to Jennings Rd on Off. Lot to # 1920 on Right. to 1 mi - house on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 2.9 acres


Character & Porosity of Soil Red Clay

Percolation Rate none

Topography Slight slope & level

Depth to Water Table wet

Rock or other impervious formations wet



Plot of System Ad # 1920

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 630 Linear Ft. 225

Depth of Stone in Lines 11"

Water Supply: Individual (✓)

Public ( )

Well Installed by Herman Likens

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M. Tolbert DATE 1 May 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold