13213

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dept. of Transportation DATE 8-9-91 PERMIT NO. 106A28

PHONE: Business _____ Home _____

LOCATION US21N on rt beside Ebenezer VFD S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Test Lab 650 gal/Day maximum 10 at Domestic sewage only


No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Character & Porosity of Soil Clayey
Percolation Rate 14
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations None

Lot Area 25 acres

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1668 Linear Ft. 556
Depth of Stone in Lines 12"+

Water Supply: Individual ( )
Public (✓)

Installed by Wes Lytton

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

100% Repair area

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: area over Drainfield should be sowed in grass & mowed on regular basis.

CERTIFICATE OF COMPLETION BY J.C. Moore DATE 8-9-97

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold