IREDELL COUNTY HEALTH DEPARTMENT

THIS PERMIT IS A REVISION of PREVIOUS ISSUED 11-12-03

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 112180 PIN# 4757-21-3798 DATE 9-21-03

OWNER OR CONTRACTOR MARTY MALTBY PHONE: Business 704-902-3907 Home

ADDRESS 3624 GORDON ST TERRELL NC 28682

LOCATION US 21 NORTH, 2ND LOT ON RIGHT PAST PRISON CAMP ROAD

SUBDIVISION BLOCK / SECTION LOT LOT AREA 2.84 ACRES SITE CLASS PS DESIGN FLOW 700 L.T.A.R. 0.30 GPD/FT2

Septic Tank: 1500 Gallons; STB 1011 Date 10-6-03

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet EQ. N° 2334 Linear Feet 590'

No Lines SIX Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☐ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: 25% REDUCTION GRAVITY

Repair System Description: 50% REDUCTION LOW PRESSURE

Maintenance Agreement Required: ☐ Yes ☒ No

☐ House/Mod. Home No. Bedrooms

☐ Mobile Home No. Bathrooms

☒ Business No. Employees

Other 6 OFFICES @ 100 GPD WITH 1 BEAUTY @ 125

☑ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☐ Community

Comments/Conditions:

Comments/Conditions: CHANGE of USE.

INITIAL SITE SKETCH

AS BUILT SKETCH

THIS PERMIT IS TO ALLOW THE USE OF AN EXISTING SEPTIC SYSTEM TO ACCOMMODATE SIX (6) OFFICE/GENERAL BUSINESS SPACES WITH ONE BEAUTY SALON/TATTOO PARLOR WITH ONE CHAIR ONLY. (AS ONE OF THE OFFICE SPACES)

SEE PREVIOUS PERMIT ISSUED 11-12-03

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 9-23-2003 Installed by:

Improvement Permit by: date Operation Permit by: date

Authorization to Construct by: date Existing System Inspection by: STEVE HEDRICK date 9-21-03

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK