IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / CERTIFICATE OF COMPLETION / OPERATION PERMIT / EXISTING SYSTEM INSPECTIO

5085

PROPERTY DESCRIPTION NO 18156 DATE 8-8-94 TAX MAP NO 10.6-A-49B Watershed: ☐ Yes ☒

OWNER OR CONTRACTOR Bobby S. Redmon PHONE: Business Home 876-3721

ADDRESS Rt 8 Box 287-B Statesville

LOCATION 21 N Past Ebenezer Ac turning To Bethany Rd on left Beside CC Trang

SUBDIVISION

AREA .63 ac SITE CLASS P.S DESIGN FLOW 360 L.T.A.R. .4

Septic Tank EX 1000 Date 6-7-88

Pump Tank

Pump Make

Nitrification Field 1 300 100

No Lines 2 36" 36" Trench Width 12"

System Description: Addition to EX system conv. Gravity

Repair System Description:

Water Supply Agreement Required ☐ Yes ☒ No

Type System: Repair, System Type I, II, III, IV, V, VI

☐ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 3

☐ Business No. Employees

☐ Other

Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply ☐ Individual ☐ Community ☒ Public

Comments: Adding to EX System installed 6-7-88 1000 gal 200' Drain line Filed under Bobby Redmon

Existing mobile Home must be Pulled off site before House is occupied

Comments:

INITIAL SITE SKETCH

10' EX. 3'X100' Lines 3' apart (3'X100' Addition) EX. S.T. EX Box House Property line Driveway To Bethany Rd

AS BUILT SKETCH

3'X50' 3'X50' EX drain line New Box S.T. EX Box House

I understand that ... information supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit is valid for 60 months from date issued.

Signed: [signature]

Improvement Permit by: E.C. Moore date 8-8-94

Existing System Inspector by: date

Installed by: A.A.A Enterprises

Certificate of Completion by: E.C. Moore date 10-6-9

Operation Permit by: date

OWNER COPY (FINAL) YELLOW INSPECTION COPY (INITIAL) PINK OWNER COPY (INITIAL) GOLD

MAR. 31, 1989 12:40