04725

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bobby Redman DATE 9-17-87 PERMIT NO.

NAME: Business Home

LOCATION 21 N TL on Bethany Rd SR 1921
Barber Shop on left. S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.

Home ( ) Mobile Home ( ) Business ( ) Other Barber Shop 1 chair


No. Bedrooms No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No ( )
Elec. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Size Suitable	Yes ( )	No ( )

Character & Porosity of Soil Prov. Suitable
Percolation Rate .2 g.i. / 3 g.i. thru
Topography Inclined
Depth to Water Table 10'
Rock or other impervious formations None

Area

____ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 1.2'
Water Supply: Individual ( )
Public (✓)

Installed by Jimmy Reavis

I understand and agree to install septic system as specified on this Improvements

The proposed shower addition does not appear to impact the existing septic system.
**NOTE:

R.S.
Date: 9-18-87
ICHD-Environmental Health Division

Plot of System

IMPROVEMENTS PERMIT BY Glenn Fox Jr.

COMMENTS:

CERTIFICATE OF COMPLETION BY DATE 9-17-87

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

JAN. 3, 1989 7:13