DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of ___
PROPERTY ID #: 4757-37-5488
COUNTY: Buncombe

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Countryme NC LLC / Tom Palmer Homes, Inc. APPLICATION DATE 10-5-09
ADDRESS: 125 Old Haw Creek Rd. Asheville, NC DATE EVALUATED: 10-19-09
PROPOSED FACILITY: 4 br House PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE: 1.45 ac.
LOCATION OF SITE: Hwy 25 N TL Maple Creek TL Rawlinwood TL Old Haw Creek Rd. PROPERTY RECORDED: ___
WATER SUPPLY: • Private • (Public) • Well • Spring • Other ___
EVALUATION METHOD: • (Auger Boring) • Pit • Cut TYPE OF WASTEWATER: • (Sewage) • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L/N 6%	0-8	gr/L	vfr/Sof	7-8	7-8	NA	NA	PS 0.3
		8-34	sbk/C	fr/Sof					
		34-48+	sbk/cl	fr/Sof					
2	L/N 6%	0-28	sbk/cl	fr/Sof	7-8	7-8	NA	NA	PS 0.7
		28-48	sbk/C	fr/Sof					
3	L/N 8%	0-7	gr/L	vfr/Sof	7-8	7-8	NA	NA	PS 0.3
		7-26	sbk/C	fr/Sof					
		26-48	sbk/cl	fr/Sof					
4	C/N 8%	0-11	gr/L	vfr/Sof	7-8	7-8	NA	NA	PS 0.3
		11-32	sbk/C	fr/Sof					
		32-48+	sbk/cl	fr/Sof					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III 25%	IV 50%
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: TCH
OTHER(S) PRESENT: ___

COMMENTS: ___