IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Somers DATE 1/18/74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N. Across from Freedom Presby. Ch. on Rt. _____

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 1 Acre

Character & Porosity of Soil Red Clay
Percolation Rate —
Topography Level
Depth to Water Table —
Rock or other impervious formations —



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines _____
Sq. Ft. 5624 Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Ray Lentz

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY [signature] DATE 1/18/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold