DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

(2)

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4757-58-6352

OWNER: MARK TAYLOR APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: MAPLE CREEK LOT 12 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut 11-2-01
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFIL CLASS & LTAF
4	10% LSS	0-3	scl			>48"			PS .25
		3-32	c, med sbk/sbk	fr ss sp si/sp					
		32-60+	c sap mix	fr ns sp mxp					
5 2	10% LSS	0-3"	scl			≥36"	PS		PS .35
		3-36"	sap mix c, med, sbk	fr ss sp scp					
		36-60"	saprolite	fr ns sp mxp					
6 3		0-3"	scl			≥24"	PS		PS .35
		3-24"	cl, med, sbk	fr ss sp scp					
		24-60	saprolite	fr, ns, sp, mxp					
7 REVISED 4	12% CC	0-5"	scl			≥72			PS .3
		5-72"	c, med, sbk	fr ss sp so					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	GRAV PANEL	LP PANEL
Site LTAR	.25	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS

EVALUATED BY: L. COOK
OTHER(S) PRESENT: K LAMBERT, M. TAYLOR