13147.

BRUNSWICK COUNTY HEALTH DEPARTMENT

SEPTIC TANK-IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

Ground Absorption Sewage Disposal System G.S. Chapter 130-Article 11C

OWNER OR CONTRACTOR JAMES R. CHRISTOPHER DATE 8-20-91 PERMIT NO 10K-A-12.

PHONE Business Home

LOCATION Hwy 211 N - driveway on left 1500' past Belle Meade Rd. - go nearly to end of F.L. - MH down in woods.

SUBDIVISION NAME LOT NO SECTION OR BLOCK NO S. R. No.

House Cottage Mobile Home Residential Other

No. Bedrooms 3 No. Bathrooms 2 Character & Porosity of Soils Prev. Suitable.

Garbage Disposal Unit No. Kitchen Sink Percolation Rate 1 mpi / sq. ft.

Auto. Dishwasher No. Floor Drains Topography 2-6% slope

Auto. Washer Machine No. Automatic Flush Depth to Water Table 10+

Solar System No. Pressure Water System Rock or other impervious formations none observed.

Lot Area 15 acres.

Basement with Plumbing Basement without Plumbing Crawl Space

Size of Tank 1000 Gals.

Sanification Field 3

No. of Lines 3

Sq. Ft. 900 Length of Lines 300


Depth of Stone or Lines 12

Water Supply Individual Public

Installed by Harry Reep

Engineer's Name and Address (If Applicable)

Name



INSPECTIONS REPORTED BY J. C. Moore

COMMENTS House to be built later with same number of bedrooms.

CERTIFICATE OF COMPLETION ISSUED BY Steve E Brown DATE 8-20-91

EXISTING SYSTEM COLLECTED BY DATE

CONSTRUCTION MEETS COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Property Owner Agent Signature

Engineer's Name Printed

Health Dept. Copy White Sanitarian Copy Yellow Installer Copy Pink Owner's Copy Gold

FEB. 26, 1989 20:32