IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Alfred Levan DATE 4-23-80 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION US21 N TL on Dunlap Gate Rd Turn 1st left 3rd lot on L S. R. No. _____


SUBDIVISION NAME Dunlap Gate LOT NO. 3 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ½ acre

Character & Porosity of Soil Cecil Clay
Percolation Rate 60 to 80 min/inch
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations none



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Don Lackey

IMPROVEMENTS PERMIT BY H. C. Moore

COMMENTS: Landscape & pipe Gutters so that surface water will not stand over Tank or lines

CERTIFICATE OF COMPLETION BY H. C. Moore DATE 4-23-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold