00454

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Johnny Hope Jr. DATE 3-12-84 PERMIT NO.

PHONE: Business Home


LOCATION 21N TR on Dunlap Gate Rd 1/3mi on L.

SUBDIVISION NAME Dunlap Gate LOT NO. 3 SECTION OR BLOCK NO. S. R. No.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	14 Gal/Sq Ft/day
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
Lot Area approx ½ acre			Rock or other impervious formations	none



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Arnie Duncan

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY L. C. Moore

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

DATE

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold