IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ralph Porter DATE 10-24-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N Go 1.7 mi Past Prison Camp on rt. S. R. No. _____

SUBDIVISION NAME Dunlap Gate LOT NO. 7 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Cecil Fine Sandy loam
Percolation Rate 60 min/inch
Topography 6 to 10%
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 100 X 350



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Don Lackey

IMPROVEMENTS PERMIT BY Andrew Causey

revised J.C. moore 10-23-78
Property line was not as indicated on lay-out

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-24-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold