IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hunter Homes DATE 10/5/77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N., T.R. on Rt # 2141, T.L. on 1st paved Road, 5th lot on Rt _____ S. R. No. _____

SUBDIVISION NAME Dunlop LOT NO. 37 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 110x182


Character & Porosity of Soil CfBg

Percolation Rate Sm Mod

Topography 6-10%

Depth to Water Table wet

Rock or other impervious formations none encountered



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 6

Sq. Ft. 1070 Linear Ft. 390

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Donald Hardy

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 10/5/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold