IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bros DATE 8-3-81 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Dunlap Gate 35

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Fine Sandy Clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	6 gal/sq' 1 hour
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6 %
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' +
			Rock or other impervious formations	none

Lot Area 18,000 Sq'

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Hope Brothers

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 8-3-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold