IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Edwin Hunter Homes DATE 8-31-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21d to Rd #2163 TR. 6. to 2nd STREET
IL - House on LEFT S. R. No. _____


SUBDIVISION NAME DUNLAP LOT NO. 29 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil		CfB2
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate		60 min
Auto. Wash. Machine	Yes (✓)	No ( )	Topography		Slight slope to left side of lot
Site Suitable	Yes (✓)	No ( )	Depth to Water Table		60"
			Rock or other impervious formations		None

Lot Area 20,000



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Arnold Lackey Inc.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Lapp Jr. DATE 8/31/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold