IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Brothers DATE 1-10-80 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION US 21 TR on 2141 TL on 2216 1/4 mi on L

S. R. No. _____

SUBDIVISION NAME Dunlap Gate LOT NO. 12 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Cecil Clay & Parent Material
Percolation Rate 80 MPI
Topography Roll
Depth to Water Table 10'+
Rock or other impervious formations ~~None~~ Some Saprolite

Lot Area 1 Lot Lines moved or not where I was told



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10" in lines
Water Supply: Individual ( ) 3' in Pits
Public (✓)

Installed by Hope Brothers

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: System had to be turned down 1st inspection due to shallow lines, they were cut off & Pits Added back as Shown. Also lot lines where not as told to me on lay-out house site was moved over approx. 15' Extra System was Added to compensate for error.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 1-10-80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold