15701

46974

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Wesley Tomlin DATE 4-20-93 PERMIT NO. 10-K-20

PHONE: Business _____ Home _____

LOCATION US 21 TL Jennings Rd TR Blackwelder Rd on Rt approx 2mi behind Harold Buss House S.R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☑ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☐ No ☑

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 200'X420'

Soil Characteristics Clayey + clay loam


Application Rate .38

Topography 2 to 6%

Depth to Water Table 10'+

Rock or other impervious formations none

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 960 Linear Ft. 320

Depth of Stone in Lines 12"

Water Supply: Individual ☐ Public ☑

Installed by Andy Daniels

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY R.C. Moore

COMMENTS 10"

CERTIFICATE OF COMPLETION BY R. C. Moore

EXISTING SYSTEM CHECKED BY _____ DATE 4-20-93

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS DATE _____

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold