IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 155539 PIN # 4758-54-3663 DATE July 19, 2010

OWNER or APPLICANT GIRL SCOUTS, HORNETS NEST COUNCIL PHONE: Business 704-731-6544 Home:

OWNER or APPLICANT ADDRESS 7007 INLEWOOD ROAD, CHARLOTTE NC 28212

LOCATION / DIRECTIONS US 21 NORTH, CROSS S. YADKIN RIVER, 1ST DRIVE ON LEFT, CAMP BACK OFF ROAD

SUBDIVISION OAK SPRINGS GIRL SCOUT BLOCK / SECTION VILLAGE #2 LOT AREA 678 AC DESIGN FLOW 312 L.T.A.R. 0.30 GPD/FT2

Septic Tank 3000 Gallons: STB 500 Date 6-20-06

Pump Tank 3000 Gallons: PT ~~1500~~ 1000 Date 1-10-09

Pump Make GOULDS Model WE10T2HH Serial # #1028712

Nitrification Field No Fields 1 No Lines 6 Linear Feet 432

Trench Width 36" Max. Trench Bottom Depth 30" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: 25% REDUCTION PUMP

Repair System Description: 25% REDUCTION PUMP

Maintenance Agreement Required ☐ YES ☒ NO

☐ GRAVITY ☒ PRESSURE

☐ Residence No. Bedrooms

☐ Business No. Persons 64

☒ Other No. Employees 6

☐ Slab ☐ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☒ Public ☐ Community

Comments / Conditions: INSTALL 25% REDUCTION DRAINFIELD ON CONTOUR, NO DEEPER THAN 36". SYSTEM NOT PERMITTED FOR FOOD SERVICE

Comments / Conditions

INITIAL SITE SKETCH

OAK SPRINGS GIRL SCOUT CAMP
SEASONAL VILLAGE #2 BATHHOUSE

SEE ATTACHED SPECIFICATIONS AND SITE PLAN PREPARED BY PIEDMONT DESIGN ASSOCIATES, PA DATED July 8, 2010

AS BUILT SKETCH

SYSTEM INSTALLED ACCORDING TO "AS BUILT" PLANS SUBMITTED BY PIEDMONT DESIGN ASSOC.

6-21-06 (1-10-09)

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☒ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Steve Hendrick Date 8-11-10

Improvement Permit by: STEVE HENDRICK Date 7/19/2010

Authorization to Construct by: STEVE HENDRICK Date 7/19/2010

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: PIEDMONT BACKHOE SERVICE, INC.

Operation Permit by: STEVE HENDRICK Date: 9-16-2010

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant

AS BUILT SKETCH BY:
STEVE JORDAN, INSTALLER

