DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 4758778532
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Ashley McCracken
ADDRESS: 1602 Davie Ave Statesville
PROPOSED FACILITY: 3BR SFD
LOCATION OF SITE: 112 Windcrest Ln
WATER SUPPLY: • Private • Public • Well • Spring • Other N/A
EVALUATION METHOD: • Auger Boring • Pit • Cut

APPLICATION DATE 3-1-13
DATE EVALUATED: 3-4-13
PROPOSED DESIGN FLOW (.1949): 360 gpd
PROPERTY SIZE: 0.487acres
PROPERTY RECORDED: Yes
TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	10% L	0-10	SC SBK	Fi Mod SE	42/48"	42/48"	42/48"	42/48"	PS 0.3
		10-29	C mica SBK	Fi Mod SE					
		29-48	CL mica WSBK	Fi Mod SE					
2	7.5% L	0-9	SC SBK	Fi Mod SE	48"	48"	48"	48"	PS 0.3
		9-30	C mica SBK	Fi Mod SE					
		30-48	CL mica WSBK	Fi Mod SE					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		PS
System Type(s)		III
Site LTAR		0.3

OTHER FACTORS (.1946): ~~PRO~~ N/A
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Justin Henderson
OTHER(S) PRESENT: David Hinson

COMMENTS: N/A