12789

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James D. Martin DATE 5-16-91 PERMIT NO. 13HA8

PHONE: Business _____ Home _____

LOCATION I-77 N TR Tomlinmill TL Josey Rd 1/4 mi TR Private Rd at end on L S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other Repair

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	PS
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4+0&2
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	>4'
			Rock or other impervious formations	none

Lot Area 2 acres

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement (old lines were cut + Earthen Dams Placed)



Plot of System

Size of Tank Existing Gals.

Nitrification Field:
No. of Lines 1
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by James Hutler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

These Portions of Ex. lines were cut off

IMPROVEMENTS PERMIT BY Steve Hetrick

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 5-16-91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold