IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

0406

OWNER OR CONTRACTOR Thomas Martin DATE 9/89 PERMIT NO. 12H-A-8

PHONE: Business _____ Home _____

LOCATION 7N R Tomlin Mill L Jersey Rd In Culdesac on Lot 4


SUBDIVISION NAME _____ LOT NO. _____ S. R. No. _____

House ( ) Mobile Home (✓) Business ( ) Other _____ SECTION OR BLOCK NO. _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Sandy Suitable
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate 37
Auto. Wash. Machine	Yes (✓)	No ( )	Topography Rolling
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 2.06 ft
Lot Area 340			Rock or other impervious formations 10 ft None

____ Basement with Plumbing ____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Evans Hall

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Peterson

COMMENTS: Keep out of last 50' from ST System

CERTIFICATE OF COMPLETION BY Peterson

EXISTING SYSTEM CHECKED BY: _____ DATE 9/18/92

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold