HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 13H - A - 38
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RALPH CHURCH OWNER: ✓ AGENT: PHONE: 663-7923
ADDRESS: RT. 5, BOX 321 APPLICATION DATE: 10/18/93 DATE EVALUATED: 10/18/93
STVL, NC 28677 PROPOSED FACILITY: 2BR MH
PROPERTY SIZE: AMPLE
LOCATION OF SITE: I-77N TR TOWLIN MILL RD, TR FAIRMOUNT CH. RD, 1ST ON (R)
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	N	0-8	C	SBK	1:1 / FR	.1942 WETNES CONDITION -
		8+	SAPROLITE			.1943/.1956 SAPROLITE U
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION U
						PROFILE LTAR -
2	H	0-6	C	WSBK	1:1 / FR	.1942 WETNES CONDITION -
		6+	SAPROLITE			.1943/.1956 SAPROLITE U
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION U
						PROFILE LTAR -
3	L	0-10	C	SBK	1:1 / FR	.1942 WETNESS CONDITION [redacted]
		10+	SAPROLITE			.1943/.1956 SAPROLITE U
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION U
						PROFILE LTAR -
4	L	0-48	C	ABK	1:1 / FI	.1942 WETNESS CONDITION S [redacted]
						.1943/.1956 SAPROLITE S [redacted]
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35
5	L	0-48	C	ABK	1:1 / FI	.1942 WETNESS CONDITION S
						.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT
OTHER FACTORS(.1946) N/A SYSTEM TYPE CONV. GRAVITY / PUMP REPAIR
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: RALPH CHURCH, FRANK CHURCH
COMMENTS: AVAILABLE SPACE FOR 2BR ONLY, 3BR WILL REQUIRE PPBPS.

DRAFT