HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: PART OF 13H-A-12A
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: HERITAGE BLDG Co OWNER: AGENT: ✓ PHONE: 528-6649
ADDRESS: RT. 10, BOX 177-A APPLICATION DATE: 10/13/93 DATE EVALUATED: 10/13/93
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 2.204 AC
LOCATION OF SITE: I-77 N, TR TOMLIN MILL RD, TL JOSEY ROAD, ~0.75 MI ON (R)
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ✓

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	N 4-6	0-6	SC	GR	1:1 / FR	.1942 WETNES CONDITION	S
		6-32	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	S
		32-48	SC	SBK	1:1 / FI	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT2
2	N 6-8	0-8	SC	GR	1:1 / FR	.1942 WETNES CONDITION	S
		8-36	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	S
		36-48	SC	SBK	1:1 / FI	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT2
3						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GPD/FT2
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: RICK DYSON / WILSON MARTIN
COMMENTS:

DRAFT