DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4759 45 4554 (PT)

OWNER: PHILLIP CHURCH APPLICANT: SAME
ADDRESS: 901 TABOR RD OWN, NC 28660 APPLICATION DATE: 3-26-01 DATE EVALUATED: 4-23-01
PROPOSED FACILITY: 3BR II W/ENG PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 2.0 ACRES
LOCATION OF SITE: 318 JOSEY ROAD (BEHIND) PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 10%	0-6	SBK SCL	VFR SEXP					PS 0.9
		6-28	MMSBK CL	FR SEXP					
		28-48	WSBK SCL	VFR SEXP					
2	L 10%	0-6	WSBK SL	VFR					PS 0.9
		6-32	MMSBK CL	FR SEXP					
		32-48	WFSBK SCL	VFR SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.9	0.9

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: PHILLIP CHURCH & WIFE