IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 119835 PIN# ~~4850-90-4452~~ 4759-89-3120 DATE 4-26-04

OWNER OR CONTRACTOR DAVID KELSO PHONE: Business (704) 882-0951 Home (704) 872-7514

ADDRESS 4274 TAYLORSVILLE HWY STATESVILLE NC 28625

LOCATION I-77 N EXIT 59 TOMLIN MILL RD - MAKE A (R) (L) RASH RD ONE MILE ON (L) NEXT TO 307 RASH RD.

SUBDIVISION _____ BLOCK / SECTION _____ LOT _____ LOT AREA 4.05 SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. EXISTING

Septic Tank: EXISTING Gallons; STB _____ Date _____
Pump Tank: _____ Gallons; PT _____ Date _____
Pump Make: _____ Model _____ Serial No. _____
Nitrification Field: No Fields 1 Square Feet _____ Linear Feet 345 EXIST
No Lines 3 EXIST Trench Width 36" Max Trench Bottom Depth 18-36" Gravel Depth 12"

☐ New System ☐ Repair System Type: I (II) III, IV, V, VI
System Description: CON. GRAVITY
Repair System Description: CON. GRAVITY
Maintenance Agreement Required: ☐ Yes ☒ No


☑ House/Mod. Home No. Bedrooms 3
☐ Mobile Home No. Bathrooms 2
☐ Business No. Employees _____
☐ Other _____
☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community

Comments:/Conditions: (1) THIS PERMIT GOES WITH PERMIT # 17002 DATED 9-15-93 UNDER NAME OF WARREN R. HILKERT.

Comments:/Conditions: (1) SYSTEM FUNCTIONING PROPERLY AT TIME OF INSPECTION (2) PERMISSION GIVEN TO CONNECT PROPOSED STRUCTURE ONTO EXISTING SYSTEM (3) NEW STRUCTURE SHALL NOT INCREASE # OF BEDROOMS ON SYSTEM (4) THE INSPECTION IS A VISUAL INSPECTION AND DOES NOT GUARANTEE PROBLEMS WILL NOT ARISE IN FUTURE. (5) NEW STRUCTURE SHALL BE A MINIMUM 5' FROM EXISTING SYSTEM.

INITIAL SITE SKETCH



Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: David Kelso date 4-26-04 Installed by: Tommy FRYE

Improvement Permit by: _____ date _____ Operation Permit by: _____ date _____

Authorization to Construct by: _____ date _____ Existing System Inspection by: Christopher Stovall, PS date 4-26-04

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK