4760 066875

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Walter Hooper DATE 2/16/88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N TR Shinnville TL Weathers Creek X 2 Bridges and Church 1st brick house on Right. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other REPAIR


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil (existing repair) clayey
Percolation Rate n .4 gpd/ft²
Topography 2%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area Existing

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System N.T.S. WEATHERS CREEK.

Size of Tank (Existing) 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Cuthberson

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY A.C.P.

COMMENTS: Washer (in basement) plumbed into new system.

CERTIFICATE OF COMPLETION BY André C. Price DATE 2/17/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Walter Hooper DATE 1/29/88 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N TR Shinnville TL Weathers Creek X 2 Bridges and Church 1st brick house on R. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other REPAIR


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil existing Cypress
Percolation Rate .49
Topography 230
Depth to Water Table 9'+
Rock or other impervious formations none observed

Lot Area EXISTING

(✓) Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System N.T.S.

Size of Tank Existing? 1000?? Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Walter Hooper

IMPROVEMENTS PERMIT BY Andrew C Price WEATHERS CREEK RD.

COMMENTS: DISCONNECT OLD LINES. CONNECT WASHING MACHINE LINE TO TANK. USE EXISTING TANK IF SUITABLE.

CERTIFICATE OF COMPLETION BY Andrew C Price DATE 1/29/88

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold