ON-SITE WASTEWATER SECTION

COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Joel Howard
APPLICANT: _____
ADDRESS: _____
APPLICATION DATE: _____
DATE EVALUATED: 2/13/98
PROPOSED FACILITY: _____
PROPOSED DESIGN FLOW (.1949): _____
PROPERTY SIZE: _____
LOCATION OF SITE: Countryview Estates #3
PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☒ Other Multi-Dwelling
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (1941) 1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	5-6%	0-12"	Brw C/Cl	S,P,SE,F					PS .25
		12"-30"	Rd/Brw C/Cl	S,P,SE,F w/Inclus of SAP					
		30-48"	Rd/Brw-Brw C/Cl & SAPs	Weathered Rock mix					
			w/ Common Mica Flakes						
2	5-6%	0-12"	Brw/Rd C/Cl	S-SS, SP SE, F					PS .3
		12"-48"	Rd/Brw-Brw C/Cl	SS,SP SE,FR w/Inclus of SAP					
			& Weathered Rock w/ Common Mica Flakes						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____