PIN 4760164329.

489

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bobby Davis DATE 6-24-22 PERMIT NO. 465

PHONE: Business _____ Home _____

LOCATION 21 N to Rt 2383 to Rt on 2379 4 mi on right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

489 Heathers Creek Rd - Iredell.

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3 acres


Character & Porosity of Soil Clay Loam Loose Fair

Percolation Rate 5 in 10 mins

Topography 2-8% Slope

Depth to Water Table 10 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250'

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Wayne Gibson

IMPROVEMENTS PERMIT BY Peter Hewitson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Peter Hewitson DATE 6-24-22

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold