0821

IREDELL COUNTY HEALTH DEPARTMENT 4760 17 7095

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bobby G. Davis DATE July 1, '88 PERMIT NO.

PHONE: Business Home

LOCATION 115 N. TR 2383 (Shinnville Rd) R 2379 (Weathers Creek Road) 1.6 mile on Rt 300'+ off road S. R. No.

SUBDIVISION NAME Davis Property LOT NO. 3 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash Machine	Yes (✓)	No ( )
Site ~~Suitable~~/S	Yes (✓)	No ( )

Lot Area 2 Ac.

Character & Porosity of Soil Clay


Percolation Rate 2, 4

Topography 15% + 4" +

Depth to Water Table

Rock or other impervious formations none obs.

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 72"

Water Supply: Individual (✓)
Public ( )

Installed by Wayne Potts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY DRH

COMMENTS: Lowest line very shallow in spots (6" cover) and needs to be mounded over an additional 6". Will not down.

CERTIFICATE OF COMPLETION BY DR Hinson, RS

EXISTING SYSTEM CHECKED BY: DATE 7-1-88

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold