DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

OWNER: Tolly Kennerly
ADDRESS: APPLICANT:
PROPOSED FACILITY: SFR APPLICATION DATE: DATE EVALUATED: 7-8-05
LOCATION OF SITE: 901 Shannville Rd PROPOSED DESIGN FLOW (.1949): 4Bdrm PROPERTY SIZE: 1 Acres
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other PROPERTY RECORDED:
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	11% L	0-40	wkSBK gr cl	frssSP SEXP	common mod SAP		probably PS 40"+		.35
		40-48	Weak massive L/SAP	fr SSSP	common mod SAP				
2	9% L	0-22	SBK RC	fr SSSP SEXP					.3
		22-48	wkSBK gr cl	fr SSSP					
3	8½% L	0-5	Wk SBK SBK sl	frssSP					.3
		5-48	SBK RC	fr SSSP SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv 25% Red	Stone
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY:
OTHER(S) PRESENT: