IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13142 PIN# 4760593725 DATE 9-28-05

OWNER OR CONTRACTOR Gra-Con Luxury Homes/Don Phone: Business 828 478-9699 Home

ADDRESS P.O. Box 62 Sherrills Ford, NC 28673

LOCATION Shinnville Rd TL Brawley Rd TR Fairhaven lot on left before Cul de sac

SUBDIVISION Fairhaven BLOCK / SECTION 1 LOT 8 LOT AREA .87 Acre SITE CLASS PS DESIGN FLOW 360gpd L.T.A.R. .25

Septic Tank: 1000 Gallons; STB 760 Date 11-8

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1080 Linear Feet 360+

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: Gravity-25% Red "Accepted System"

Repair System Description: LP Panel Blk.

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☐ Other

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments/Conditions: Septic permit approved for attached plan, designed by Rollins Soil & Environmental Services.

Comments/Conditions: 3/29/07 Reviewed Floor plan, essentially in Compliance with original plan.

INITIAL SITE SKETCH

See attached plan & drawing for Septic System Layout.

AS BUILT SKETCH

Redpro 4 lok filter

Installed Quick 4 Std Infiltrator

92', 84', 92', 92' / 360' total

with 4 drop boxes

House not built at time of inspection

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Brenda Fernandez date

Improvement Permit by: Maria H. Colon RS date 9/28/05

Authorization to Construct by: Maria H. Colon RS date 3/29/07

Installed by: Abee's Grading

Operation Permit by: Judy Melville date 4-26-07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK