DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: JAMES SANFORD OWNER: ✓ AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 7/27/93
PROPOSED FACILITY: 380-2BA 1/2 BASE W/O PLUMB
PROPERTY SIZE:
LOCATION OF SITE: SHINVILLE RD ON (L) JUST BEFORE BRAWLEY RD.
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

| PROFILE # | .1940 LANDSCP POS. (%) | HORIZON DEPTH (IN.) | .1941 STRUCTURE/TEXTURE | .1941 MINERALOGY/ CONSISTENCE | .1942 WETNESS COND. | .1944 RESTRICT HORIZONS | .1948 CLASS OF HORIZ | 1943/ 1956 SAPRLT CLASS. | HORIZON LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | LCV 5% | 0-7 | gr 0/1 | 1:1 | WSO-WPO | No | S | NA | |
| | | 8-13 | sbk 2 cl | ↓ | WSO-WPS | | | | |
| | | 14-28 | wk sbk 2 sicl | ↓ | WSO-WPS | | | | |
| | | 29-41 | gr 1 sicl | 1:1 | WSO-WPO | SAP | P | IIP | .25-.3 |
| | | 42 | gr 2 SAP. | 1:1 | WSO | | | | |
| 2 | | | | | | | | | |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |
| 5 | | | | | | | | | |

AVAILABLE SPACE (.1945) P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .25-.3
EVALUATED BY: SPARKS OTHER(S) PRESENT: JAMES SANFORD
COMMENTS: TRICKY CONTOURS - TRENCHES NO DEEPER THAN 36"
DIVERSION DITCH IN FRONT - WATCH ROAD R/W