IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR michael moore DATE 4-10-86 PERMIT NO. 169

PHONE: Business _____ Home _____

LOCATION US 21 N TR on Shinnville Rd T Lon Brawley Rd cross creek 1st mH on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil clayey
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate 14 sal 5 5 1 day
Auto. Wash. Machine	Yes (✓)	No ( )	Topography 2 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10+
			Rock or other impervious formations none

Lot Area acreage

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by James Hustler

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Charles Barnett

COMMENTS: _____

CERTIFICATE OF COMPLETION BY F. C. Moore DATE 4-10-86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold