DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Billie Thornton APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 12-2-05
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: ___
LOCATION OF SITE: lot 3 Strawberry Hills PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-4	brn scl	fr sssp					.225
		4-43	wk sbk yR C	fr sssp stxp - common yb rw mottles					.3
		43-48	wk. mssl R c/cL	fr sssp stxp - abundant mottles					
2		0-4	gr brn scl	fr sssp					.25
		4-36	sbk RC	fr sp-sssp stxp few - common yb rw mottles					
		36-48	wk sbk yR cL	fr sssp few yb rw mottles					
3	25%	0-8	gr wk sbk scl	fr sssp					.225-.25
		8-38	sbk R C	fr sssp stxp few - common yb rw mottles					
		38-48	wk sbk yR cL	fr sssp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	RS	RS
System Type(s)	Trench 24" Bed	Trench 24" Bed
Site LTAR	.225	.225

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): RS
EVALUATED BY: [signature]
OTHER(S) PRESENT: ___