DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Billie Brawley / James VanHoy APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 4-2-05
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: ___
LOCATION OF SITE: Lot 1 Stonehaven Hills PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-6	GRVSCL	FRSSP					.25-.3
		6-24	SBK RC	FRSSSP few f red mottles					
		24-48	WK SBK YR CL	FRSSP					
				few ins SAP 48"+					
2	4% S/L	0-5	GRVSCL	FR					.3
		5-40	SBK RC	FRSSPSSP few ins SAP					
		40-48	WK SBK CL	FRSSP common ins SAP					
3		0-22	SBK RC	FRSSPSSP					.3
		22-48	WK SBK YR CL	few FRSSP few common ins SAP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Gravity 25% Red	Gravity 25-50% Red
Site LTAR	.25-.3	.25-.30

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DM Hamm
OTHER(S) PRESENT: ___