...SION OF ENVIRONMENTAL HEALTH
...-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

...NER: _____ APPLICANT: _____
...DRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 3/10/05
...OPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
...CATION OF SITE: Shiloville Estates lot 4 PROPERTY RECORDED: _____
...TER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
...ALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
...PE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
	0-6	SCL GR	FR SS SP					PS
	6-24	RBCL WSBK	FR SS SP					1.3
	24-35	RCL WSBK	FR SS SP	Many Inc of SAP				.9
	35-53	L SAP	FI NS NP					
	0-8	SiCL GR	FR SS SP					PS
	8-47	RC/CL MPSBK	FR SS SP					1.3
	47-54	CL WSBK	FR SS SP	(Inc of S-P)				
	0-10	BSCL GR	FR SS SP					PS
	10-27	YBRC SBK	FR SS SP	Many Mica Flakes				1.3
	27-58	CL WSBK	FR SS SP	Inc of SAP				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
...ilable Space (.1945)		
...tem Type(s)		
...LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____