ION OF ENVIRONMENTAL HEALTH:
ITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

ER: _____ APPLICANT: _____
RESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
POSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
ATION OF SITE: Lot 12 Shinville Estates PROPERTY RECORDED: _____
ER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
LUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
E OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1)	0-8	SiL GR	FRI SSSP					PS .3
	8-36	RC/HyCl MSBK	FFI SSSP					
	36-60	YRCl	WSBK FRI SS SP	- Many Inc of SAP				
2)	0-8	SiL GR	FRI SSSP					PS .25 to Y2"
	8-24	RC	SBK FRI SP					
	24-42	YRC/Cl MSBK	FRI S,SP	- YBrown motes				
	Y2-62	YRC SBK/MSBK	FI S,SP	- ≤2 Chromas "Tiger Dirt" (@ at Y2")			(30" Trench Bottom)	
3)	0-12	BSiL GR	FRI SSSP					PS .3
	12-61	RC/L MSBK	FRI SSSP	Few Inc of YB & SAT				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
able Space (.1945)		
m Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____