SION OF ENVIRONMENTAL HEALTH:
ITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

ER: _____ APPLICANT: _____
RESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 3-10-00
POSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
ATION OF SITE: Lot 14 Shingle Estates PROPERTY RECORDED: _____
ER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
LUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
E OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
	0-6	WSBk CL	FR SS SP					PS .3
	6-33	MSBk BR/YR CL/HC	FH S,P	Zone of rock between 33-38"				
	33-65	WSBk CL/L	FR SS SP					
				look	Better	36"+		
	0-16	Gr WSBk brn/yr L fr ss sp						PS .3
	16-46	SAB red/yr fr ss sp						
	46-64	WK SAB/m L sap few w/ rock fr ss sp						
w/ slight	0-18	compacted cl/c VFi						PS .25 > 24"
	18-34	WK SAB brn/yr cl/c fr ss sp	heavy clay	few - common mg gravel coatings				
	34-48	WK SAB/m gr/yr cl/c fr ss sp		few fairy tubules				
	0-5	SAB brn/yr/dk cl/c						PS .25-.3
	5-25	SAB R/YR cl/c fr ss sp						
	25-60	WK SAB/m yr cl/L fr ss sp						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
able Space (.1945)		
n Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____

EVALUATED BY: _____
OTHER(S) PRESENT: _____