DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

OWNER: Roger Overcash APPLICATION DATE: ___
ADDRESS: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): 360 gpd DATE EVALUATED: 5-29-03
LOCATION OF SITE: Lot 26 Shamrock Est. PROPERTY SIZE: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	6-8%	0-5	wk sbk sandy l	friasp					
		5-23	wk-m fsbk rc	friasp sl sty					
		23-53	wksbk Moisture light brn	fsl sm friasp					or 3
2		0-10	sandy l	fri sp (very) sl/c mix					
		10-20	mbk rc	fri sp sl sty					
		20-46	mfsbk rcl	fri sp common many mic sp					.3
3		0-9	sandy l						
		9-20	mbk, rc	fri sp sl sty					
		20-40	wksbk cl	fri sp many mic sp					.3
		40-56	wksbk sl sty	sandy l fri sp					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv.	Conv.
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DHT
OTHER(S) PRESENT: ___

COMMENTS: ___