2.00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 112345 PIN# 4760-96-5356.20 4760-96-8320 DATE Nov. 6, 03

OWNER OR CONTRACTOR Overcash Land & Development / Fleetwood Homes PHONE: Business _____ Home _____

ADDRESS P.O. Box 3846, Mooresville N.C.

LOCATION 115 N TR Shinnville Rd x Creek TL Sonoma TR Electra Drive on Right

SUBDIVISION Shinnville Estates BLOCK / SECTION II LOT 20 LOT AREA 2.106 Ac SITE CLASS 15 DESIGN FLOW 360 gpd L.T.A.R. .02

Septic Tank: 1000 Gallons; STB 1160 Date 7-13-04

Pump Tank: 1000 Gallons; PT 319 Date 6-10-04

Pump Make: ZoGould's Model LW Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1800 Linear Feet 600

No Lines 4@150' Trench Width 36" Max Trench Bottom Depth 16" Gravel Depth 12"

☐ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: pm * shallow conventional

Repair System Description: LPP or III shallow conv.

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home No. Bedrooms 3

☑ Mobile Home No. Bathrooms 2

☐ Business No. Employees _____

☐ Other _____

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community

1/24

Comments/Conditions: 333.76

INITIAL SITE SKETCH

4" Sch 80 → pm

Low

Repair Area

Proposed

House 60' 32'

70'

20' Easement

80'

275.42'

271.59'

Comments/Conditions:

* Installer note 16" max trench bottom depth (8" imported PS soil cap required)

Filter installed

Checked tanks, lines, press

Test alarm 9/2/04

AS BUILT SKETCH

Installed essentially as Drawn.

* Installer will bring in extra fill to cover

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date _____ Installed by: Buck's Grading

Improvement Permit by: 321.10' date 11-6-03 Operation Permit by: _____ date 9.9/2/04

Authorization to Construct by: _____ date 7/29/04 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK