DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: KRISTI MURDOCK
ADDRESS: 167 NACHO LN
PROPOSED FACILITY: SINGLE WIDE PROPOSED DESIGN FLOW (.1949): 240
LOCATION OF SITE: _____
APPLICATION DATE _____
DATE EVALUATED: _____
PROPERTY SIZE: ~1 AC
PROPERTY RECORDED: _____

WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
#4		0-12	CL MSBK	SSSP SEXP	—	—	PS	—	.35
		12-31	CMSBK	SSSP SEXP					
		31-	LSAP	NSNP					
#2	<2% BORING #1	0-12	CLMSBK	SSSPSEXP	—	31"	PS	—	.35
		12-31	CMSBK	SSSPSEXP					
		31-	LSAP	NSNP					
#3	<2% PIT #1	0-30	CMSBK	SSSPF	RED	70"	—	—	.35
		30-60	CLMSBK	SSSPVF					
		60-70	CLMSBK	SSSFVF	MANY MICA + SAP				
#5	<2% PIT #2	0-12	COMPACTION			70"	—	—	.3
		12-30	CMABK	SSSPF	YIR				
		30-70	CLMSBK	SSSPVF	YIR MANY MICA + SAP				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	CON STONE	CON STONE
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: SA
OTHER(S) PRESENT: _____

COMMENTS: _____