DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Leslie Elkin — APPLICATION DATE _____
ADDRESS: Weathers Creek Rd. — DATE EVALUATED: _____
PROPOSED FACILITY: SFD — PROPOSED DESIGN FLOW (.1949): _____ — PROPERTY SIZE: _____
LOCATION OF SITE: Oakridge Lot 9 — PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut — TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 2%	0–24	mSbk C	Pr SS Sp Sexp					PS .3
		24–46	wSbk C	Pr SS Sp Sexp					
2	L 5%	0–15	Gr L VB	VFr SS Sp Sexp	Few rock inc				PS .3
		15–35	mSbk C ted	Pr SS Sp Sexp	few COA inc. at 25"–35"				
		35–45	mSbk C	no rigidity					
3	L 1–2% *	0–10	Gr L YB	VFr SS Sp Sexp	few rock inc				PS .25 Restrictive horizon 26"
		10–27	Gr L RB	VFr SS Sp Sexp	few Clay inc.				
		27–38	mSbk C	Pr SS Sp Sexp	rock, sap inc.				
		38–42	mSbk C	Pr SS Sp Sexp	WB + Gray + common rock			23 27	
		water table at 38"							
4	L 3%	0–18	mSbk C	Pr SS Sp Sexp	few sap				PS .3
		18–27	mSbk C	Fr SS Sp Sexp					
		27–47	mSbk C	Pr SS Sp Sexp	Com sap				

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25% Red	25% Red
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Anthony Cobos
OTHER(S) PRESENT: Owner