IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 138856 PIN# 4761 02 4553

OWNER OR APPLICANT Corinthian Dev. DATE 8/24/07

ADDRESS PO Box 3421 Mooresville, NC. 28117 PHONE: Business 704-400-1258 Home

LOCATION Shimmill Rd TL Weatherbeak Creek on (L) just past subdivision road.

SUBDIVISION Oakridge BLOCK / SECTION LOT 14 LOT AREA .67B SITE CLASS PS DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: 1000 Gallons; STB Date

Pump Tank: 1000 Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 900 Linear Feet 300

No Lines 3@100' Trench Width 3' Max Trench Bottom Depth 30" Gravel Depth No

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: Pres Man. to 25% Reduction

Repair System Description: Same Type

Maintenance Agreement Required: ☐ Yes ☒ No

☐ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions: Trench depth 30" maximum; lines on contour as flagged in field; No variations without ICHD approval.

Comments:/Conditions: Blue Polylok filter ST w/ marker

INITIAL SITE SKETCH

Fast Track Redraw prepared by Kolland Soil & Environmental Svcs. 704-658-1723. Installer must have spec sheet and site plan for drainfield on site during installation and inspection process.

AS BUILT SKETCH

Quick-4 Infiltrator 3@100' installed per initial site sketch

manifold ok pressure set 2'

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: [signature] date 9-19-07

Improvement Permit by: Wesley Sparks R.S. date 8/24/07

Authorization to Construct by: Wesley Sparks R.S. date 8/24/07

Installed by: Corinthian

Operation Permit by: Wesley Sparks R.S. date 10/4/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK