See attached permit #160679 for pool barn addition on site. CF

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 131507 PIN# 4761-03-6758 DATE 10-13-05

OWNER OR CONTRACTOR TERESA NEWTON Carl Hershberger PHONE: Business 704-363-6904 Home 828-478-2330

ADDRESS 925 SHEPHERDS ROAD, TROUTMAN NC 28166

LOCATION US 21 SOUTH TL OSWALT AMITY ROAD ~ ¼ MILES ON LEFT AT BOX #915

SUBDIVISION WESTMORELAND AC BLOCK / SECTION ____ LOT 1 LOT AREA 2.033 ACRES SITE CLASS PS DESIGN FLOW ~~480~~ 360 L.T.A.R. 0.25 GPD/FT²

Septic Tank: 1000 Gallons; STB 760 Date 8-26-05
Pump Tank: 1000 Gallons; PT 363 Date 9-20-05
Pump Make: ZOELLAR Model BN 152-A Serial No. ____
Nitrification Field: No Fields 1 Square Feet ~~1920~~ 1920 Linear Feet 480
No Lines FOUR Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Existing System I II III IV V VI
System Description: ~~25%~~ REDUCTION PUMP
Repair System Description: 50% REDUCTION LOW PRESSURE
Maintenance Agreement Required: ☐ Yes ☑ No ☐ Other ____

☑ House/Mod. Home No. Bedrooms 4 3
☐ Mobile Home No. Bathrooms ____
☐ Business No. Employees ____
☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☑ Individual ☐ Public ☐ Community
WELL

Comments:/Conditions: ① SEE ATTACHED SHEETS FOR PUMP AND PRESSURE MANIFOLD REQUIREMENTS
② INSTALL ~~25%~~ REDUCTION SYSTEM AS SHOWN/ CONVENTIONAL (FOR 3BR HOME)

Comments:/Conditions: ③ Accepted systems may also be used.
11-3-05 Approved 3 BEDROOM PLAN 60x27, MAINTAIN SETBACKS,

INITIAL SITE SKETCH

SEE ATTACHED SITE PLAN BY ROLLANS SOIL & ENVIRONMENTAL SERVICES DATED OCTOBER 7, 2005

AS BUILT SKETCH

SEPTIC TANK WITH MARKER INSTALLED USING "ZABEL" FILTER, SYSTEM INSTALLED ACCORDING TO ATTACHED SITE PLAN BY ROLLANS SOIL & ENV. SERVICES,

Site address: 915 Ostwalt Amity Rd.

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Teresa Newton for date ____ Installed by: ABEE'S GRADING

Improvement Permit by: STEVE HEDRICK date 10-13-05 Operation Permit by: ____ date 5-7-06

Authorization to Construct by: ____ date 11-3-05 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK